

**Continuous Radon Monitor**

Model Number: 1028  
 Calibration Date: 06/05/2023  
 Monitor Time: 12/11/2023 19:33  
 Wind: NA  
 Year Built: 2023  
 Mitigation System: Not Installed  
 SqFt: NA

Serial Number: 57077103  
 CF: 2.48

**Billing Information**  
 400 Anglers Dr., Unit #113  
 Steamboat Springs, CO-80487

**Site Information**

400 Anglers Dr., Unit #113  
 Steamboat Springs, CO-80487  
 Atmospheric Condition: Recent Snow Fall  
 Structure Type: Apartments  
 Monitor Location: 1st Floor

**Test Summary**

Start Time: 12/08/2023 18:49  
 End Time: 12/11/2023 10:49  
 Measurement Interval(hr): 1.0  
 Exposure Time: 2 Days 16 hrs

Overall Avg: 2.2 pCi/l EPA Avg: 2.2 pCi/l

**Test Location:**

400 Anglers Project  
 Unit #118  
 Steamboat Springs, CO 80487

Bldg. Type: Residential Multi-Family

**Test Device Details:**

Serial Number: 241816001  
 Model Number: 1028XP  
 Last Calibration: 06/28/2023  
 Next Calibration: 06/28/2024  
 Cal-Factors: 2.76  
 Motion Error: No

**Test Site Condition:**

Condition: Recent Snowfall  
 Structure Type: Apartment Building  
 Year Built: 2023

**Test Summary:**

<u>CRM Location:</u>	<u>Start:</u>	<u>Stop:</u>	<u>Interval:</u>	<u>Duration:</u>
Ground Floor Apartment	12/08/2023 04:35 PM	12/10/2023 04:35 PM	1 hr	48 hr

*First 4 hrs of data excluded	<u>Min:</u>	<u>Max:</u>	<u>Average:</u>	<u>Measurement Units:</u>
Radon Concentration:	0.0	4.3	1.5	pCi/l

**Test Location:**

Anglers 400 Project  
 Unit #111  
 Steamboat Springs, CO 80487

Bldg. Type: Residential Multi-Family

**Test Device Details:**

Serial Number: 240328014  
 Model Number: 1028XP  
 Last Calibration: 08/02/2023  
 Next Calibration: 08/02/2024  
 Cal-Factors: 2.76  
 Motion Error: Yes

**Test Site Condition:**

Condition: Recent Snowfall  
 Structure Type: Apartment Building  
 Year Built: 2023

**Test Summary:**

<u>CRM Location:</u>	<u>Start:</u>	<u>Stop:</u>	<u>Interval:</u>	<u>Duration:</u>
Ground Floor Apartment	12/08/2023 04:03 PM	12/10/2023 04:03 PM	1 hr	48 hr

*First 4 hrs of data excluded	<u>Min:</u>	<u>Max:</u>	<u>Average:</u>	<u>Measurement Units:</u>
Radon Concentration:	0.0	2.5	1.0	pCi/l