



## Radon Test Results Hockett Gulch Apartments

Serial Number	Start Date	Start Time	Stop Date	Stop Time	Temp °F	Room	Test Result	Floor	Average	OK or FIX	Comments
<b>Building 2</b>											
20726401	04/16/2024	2:00PM	11/06/2023	16:00	65°	2102	lost				
20726402	04/16/2024	2:00PM	11/06/2023	16:00	65°	2106	lost				
20726403	04/16/2024	2:00PM	11/06/2023	16:00	65°	2202	<0.3	2		OK	
20726404	04/16/2024	2:00PM	11/06/2023	16:00	65°	2211	<0.3	2		OK	
20726405	04/16/2024	2:00PM	11/06/2023	16:00	65°	2302	0.6	3		OK	
20726406	04/16/2024	2:00PM	11/06/2023	16:00	65°	2307	<0.3	3		OK	
20726407	04/16/2024	2:00PM	11/06/2023	16:00	65°	2209	<0.3	2		OK	
20726408	04/16/2024	2:00PM	11/06/2023	16:00	65°	2105	<0.3	1		OK	
20726409	04/16/2024	2:00PM	11/06/2023	16:00	65°	2107	1.1	1		OK	
20726410	04/16/2024	2:00PM	11/06/2023	16:00	65°	2108	<0.3	1		OK	
20726411	04/16/2024	2:00PM	11/06/2023	16:00	65°	2101	1.7	1		OK	
<b>Building 3</b>											
20726432	04/16/2024	2:00PM	11/06/2023	16:00	65°	3112	<0.3			OK	
20726434	04/16/2024	2:00PM	11/06/2023	16:00	65°	3201	<0.3			OK	
20726435	04/16/2024	2:00PM	11/06/2023	16:00	65°	3108	0.6			OK	
20726436	04/16/2024	2:00PM	11/06/2023	16:00	65°	3106	0.5			OK	
20726442	04/16/2024	2:00PM	11/06/2023	16:00	65°	3103	<0.3			OK	
20726443	04/16/2024	2:00PM	11/06/2023	16:00	65°	3105	<0.3			OK	
20726444	04/16/2024	2:00PM	11/06/2023	16:00	65°	3108	NR				
20726447	04/16/2024	2:00PM	11/06/2023	16:00	65°	3102	1.4			OK	
20726448	04/16/2024	2:00PM	11/06/2023	16:00	65°	3101	0.9			OK	
20726449	04/16/2024	2:00PM	11/06/2023	16:00	65°	3104	0.9			OK	